

Ann: 17(B) fire safety

## TO WHOM IT MAY CONCERN

Certified that I have inspected the school building of **SHREE DADIJI MANDIR TRUST PRABHAVATI PUBLIC SCHOOL** at Pipalpadar, P.S – Titilagarh on 04.02.2014 to ensure the fire safety measures.

The school building having 29 nos rooms in ground floor and 03 rooms in 1<sup>st</sup> Floor which are under construction. The building is surrounded by a compound wall. There is internal wiring electrification water facility available through bore well with 2 H.P. Motor connections. Besides one water tanker having 5000lt capacity is provided. Over head tank is also provided. Ventilation to each room is provided. The school Management has provided two Co<sub>2</sub> type fire extinguishers and 06 nos fire buckets as fire safety measures. Sufficient spaces available for evacuation in case of any emergency.

### ADVISE

School building should be free from inflammable of toxic materials, cooking of food should be done at a safe place away from the building where students are located for education. Thatch or other combustible materials should not be used in the construction. Good house keeping always should be ensured. Teachers and other staffs should be sensitized to their responsibility for the safety and well being of the students. They should be trained the operation use of fire extinguishers in case of emergency. School emergency plan be made and evacuation drill, mock drill should be conducted at regular interval. Trained safety personals should be engaged in the school.

Here with No-objection certificate is being issued in favour of Shree Dadiji Mandir Trust Prabhavati Public School at-Pipalpadar, Titilagarh for the year 2014-15

Memo No 127 /TTGFS Dt. 04.02.2014


Copy submitted to the principal, Shree Dadiji Mandir Trust Prabhavati Public School, Pipalpadar for favour of information and necessary action.

  
PRESIDENT


Shree. Dadiji Mandir Trust  
Prabhavati Public School  
Pipalpadar  
Titilagarh (Orissa)



PRINCIPAL  
Shree Dadiji Mandir Trust  
Prabhavati Public School  
Pipalpadar, Titilagarh  
Bolangir (ORISSA)

  
7/2/14  
Station Officer

Titilagarh Fire Station  
STATION OFFICER  
Titilagarh Fire Station

  
7/2/14  
Station Officer

Titilagarh Fire Station  
STATION OFFICER  
Titilagarh Fire Station